*The free Adobe Reader may be used to view and complete this form. However, software must be purchased to complete, save, and reuse a saved form.

File Original with DWR

State of California

Well Completion Report

Refer to Instruction Pamphlet

No. xxxxxxx

Page 1 of 1

Owner's Well Number Domestic 1

Date Work Began 11/03/2019 Date Work Ended 11/12/2019

Local Permit Agency Solano County Environmental Health Services

Permit Number W2019-0149 Permit Date 10/22/19

DWR Use Only – Do Not Fill In

State Well Number/Site Number

N W

Latitude Longitude

APN/TRS/Other

Geologic Log

Orientation ◉ Vertical ○ Horizontal ○ Angle Specify

Drilling Method Direct Rotary Drilling Fluid Bentonite mud

Depth from Surface Feet	to Feet	Description Describe material, grain size, color, etc
0	40	Brown Clay
40	50	Fine Sand
50	87	Gravel
87	120	Brown Clay

Total Depth of Boring 120 Feet

Total Depth of Completed Well 100 Feet

Well Owner

Name Veraison Management LLC

Mailing Address P O Box 2029

City Sonoma State CA Zip 95476

Well Location

Address Ledgewood Road

City Fairfield County Solano

Latitude 38 Deg. 276 Min 20 Sec. N Longitude 122 Deg 105 Min. 621 Sec W

Datum Dec. Lat. Dec. Long.

APN Book 0026 Page 230 Parcel 020

Township Range Section

Location Sketch

(Sketch must be drawn by hand after form is printed.)

North

West East

South

Illustrate or describe distance of well from roads, buildings, fences, rivers, etc. and attach a map. Use additional paper if necessary. Please be accurate and complete.

Activity

◉ New Well

○ Modification/Repair

○ Deepen

○ Other

○ Destroy

Describe procedures and materials under "GEOLOGIC LOG"

Planned Uses

◉ Water Supply

☐ Domestic ☐ Public

☑ Irrigation ☐ Industrial

○ Cathodic Protection

○ Dewatering

○ Heat Exchange

○ Injection

○ Monitoring

○ Remediation

○ Sparging

○ Test Well

○ Vapor Extraction

○ Other

Water Level and Yield of Completed Well

Depth to first water 40 (Feet below surface)

Depth to Static Water Level 12 (Feet) Date Measured 11/12/2019

Estimated Yield * 100 (GPM) Test Type Air Lift

Test Length 8.0 (Hours) Total Drawdown (Feet)

*May not be representative of a well's long term yield.

Casings

Depth from Surface Feet	to Feet	Borehole Diameter (Inches)	Type	Material	Wall Thickness (Inches)	Outside Diameter (Inches)	Screen Type	Slot Size If Any (Inches)
0	60	16	Blank	SDR17PVC	.5	8.5		
60	90	16	Screen	SDR17PVC	.5	8.5	Milled Slots	0.032
90	100	16	Blank	SDR17PVC	.5	8.5		

Annular Material

Depth from Surface Feet	to Feet	Fill	Description
0	5	Cement	Cement
5	22	Bentonite	3/8 Chips
22	120	Filter Pack	SRI# 8 Filter Pack

Attachments

☐ Geologic Log

☐ Well Construction Diagram

☐ Geophysical Log(s)

☐ Soil/Water Chemical Analyses

☐ Other

Attach additional information, if it exists

Certification Statement

I, the undersigned, certify that this report is complete and accurate to the best of my knowledge and belief

Name Parks Water Resources (Person, Firm or Corporation)

P O Box 494 (Address) Zamora (City) CA (State) 95698 (Zip)

Signed (C-57 Licensed Water Well Contractor) 11/11/2019 (Date Signed) 972963 (C-57 License Number)

DWR 188 REV 1/2006

IF ADDITIONAL SPACE IS NEEDED, USE NEXT CONSECUTIVELY NUMBERED FORM